



U.S. Department
of Transportation
Federal Aviation
Administration

ORLANDO AIRPORTS DISTRICT OFFICE
5950 Hazeltine National Dr., Suite 400
Orlando, Florida 32822-5003
Phone: (407) 812-6331 Fax: (407) 812-6978

June 9, 2008

Mr. Chip Seymour, C.M.
Director of Planning
Jacksonville Airport Authority
Jacksonville International Airport
P.O. Box 18018
Jacksonville, FL 32229-0010

Dear Mr. Seymour,

RE: Craig Municipal Airport (CRG), Jacksonville, Florida
Draft Airport Layout Plan Comments

We have reviewed the Airport Layout Plan (ALP) transmitted by your consultant's April 28, 2008 correspondence. The following comments should be incorporated into the final ALP:

- Currently, there is no Runway Safety Area (RSA) determination file for CRG. An RSA determination will be made with information presented on the ALP and in the Airport Master Plan. Please ensure the accuracy of this data.
- Runway Safety Areas (RSAs) are not clearly depicted on the ALP drawing. Please ensure the RSAs are easily identified.
- It appears the localizer building will be in the RSA once Runway 14-32 is extended. This building will need to be relocated as localizer locations are not deemed 'fixed by function'.
- If available, please provide a VFR windrose in addition to the IFR and all-weather windroses.
- FAA Records indicate Runway 14-32 measures 4,008 feet, not 3,998 feet as shown on the ALP. Please verify the runway length.
- Please clearly depict the existing and future MALSR, glideslope, and localizer for Runway 14-32.
- Existing and future glideslope and localizer critical areas should be shown on the ALP.
- The VORTAC should be protected by a VOR critical area.
- Future RPZ lands falling off airport should be protected through future acquisition or avigation easements.
- On Sheet 9, the runway end does not match up between the plan and profile view.
- Sheet 10, the approach surface to the future runway end should be shown.

- In the interest of time, the Airport Property Map/Exhibit A was not thoroughly reviewed at this time. We will review this document and provide any comments on this sheet prior to final agency ALP comments.

Once you have addressed these comments, please forward five (5) copies of the ALP Set to this office in my attention for agency coordination.

If you have any questions, please feel free to contact me at (407) 812-6331, ext. 122.

Sincerely,

Original Signed By

Rebecca R. Henry
Program Manager
Planning and Compliance

cc: Tricia Fantinato, LPA Group, Inc., Tampa